

Årsaksmodellering i offshore risikoanalyser - Scenarioer og aktiviteter

ESRA seminar, Oslo 8. februar 2011


Eivind Økstad, SINTEF

Initierende hendelser

Initiating Event Type	Initiating Events
A. Technical degradation of system	<ol style="list-style-type: none">1. Degradation of valve sealing2. Degradation of flange gasket3. Loss of bolt tensioning4. Fatigue5. Internal corrosion6. External corrosion7. Erosion8. Other causes
B. Human intervention introduction latent error	<ol style="list-style-type: none">1. Incorrect blinding/isolation2. Incorrect fitting of flanges or bolts during maintenance3. Valve(s) in incorrect position after maintenance4. Erroneous choice or installations of sealing device5. Maloperation of valve(s) during manual operation*6. Maloperation of temporary hoses.
C. Human intervention causing immediate release	<ol style="list-style-type: none">1. Break-down of isolation system during maintenance.2. Maloperation of valve(s) during manual operation*3. Work on wrong equipment, not known to be pressurised
D. Process disturbance	<ol style="list-style-type: none">1. Overpressure2. Overflow / overfilling
E. Inherent design errors	<ol style="list-style-type: none">1. Design related failures
F. External events	<ol style="list-style-type: none">1. Impact from falling object2. Impact from bumping/collision

Basert på empiri ~100 lekkasjer > 0.1 kg/s

Initierende hendelser og arbeidsoperasjoner



Type of Initiating Event	Type of operation		Pressurised equipment		Depressurised equipment		Other work in process area	Quantity of equipment
	Normal operation	Preventive maintenance/Inspection	Sampling	External	Major unit	Small unit		
A1 Degradation of valve sealing								X
A2 Degradation of flange gasket								X
A3 Loss of bolt tensioning								X
A4 Fatigue								X
A5 Internal corrosion								X
A6 External corrosion								X
A7 Erosion								X
A8 Other								X
B1 Incorrect blinding/isolation					X	X		
B2 Incorrect fitting of flanges or bolts during maintenance					X	X		
B3 Valve(s) in incorrect position after maintenance		X			X	X		
B4 Erroneous choice of installations of sealing device					X	X		
B5 Maloperation of valve(s) during manual operations	X	X			X	X		
B6 Maloperation of temporary hoses	X				X	X		
C1 Break-down of isolation system during maintenance (technical)					X	X		
C2 Maloperation of valve(s) during manual operation	X	X	X		X	X		
C3 Work on wrong equipment (not known to be pressurised)					X	X	X	
D1 Overpressure	X							
D2 Overflow/over filling	X							
E1 Design related failures								X
F1 Impact from falling object				X	X	X	X	
F2 Impact from bumping/collision				X	X	X	X	

Arbeidsoperasjoner

Empiri

- Empiri viser inngrisen i HC-systemer kan medføre ulike initierende hendelser

Utfordring

- Hvordan etablere sammenhengen mellom arbeidsoperasjon og initierende hendelse utover det empirien viser?
- Hvordan etablere sammenhengen mellom initierende hendelse og lekkasje?

Svar

- Identifisere kontekst og oppgaver



Oppgaveanalyse inngrep i HC-system

- Oppgaveanalyser inngrep i HC-system er hentet fra OTS og anvendt for å identifisere:
 - Sammenhenger - hvilken type initierende hendelse kan oppføre når
 - Aktører - hvem og hvor mange
 - Type oppgave – utfører eller kontroll med eller uten bruk av sjekklister


Oppgaveanalyse inngrep i HC-system

Oppgaveanalyser av
ingrep i HC - system
er hentet fra OTS og
anvendt for å
identifisere:


Sammenhenger -
Hvilke typer initierende
hendelse kan opptre,
og hvordan/når

Aktører -
Hvem, og hvor mange


Type oppgave -
Utførende eller
sluttkontroll, med eller
uten bruk av sjekklisten



Hendelsestre



Hendelsestre og feiltre



Hendelsestre, feiltrær og risikopåvirkende faktorer (RIF)

